BILL OF MATERIALS
GENERAL NOTES
1. ALL PIPING IN QUARTERS, MESS AND GALLEY PUBLIC SPACES AND NAVIGATING SPACES SHALL BE CONCEALED.
2. ALL VALVES AND VALVES SHALL BE MARKED SHOWING ITS SERVICE AND PARTICULAR LIQUID.
3. ALL PIPING SHALL BE COLOR CODED IN ACCORDANCE WITH MIL-STD-101 AND SHALL INDICATE DIRECTION OF FLOW.
4. SANITARY SYSTEM USE GALV. STL. PIPE ASTM A53 GR B W/ MIL GALV. FITTINGS ASTM A-47.
5. ALL PIPES SUBJECT TO MECHANICAL INJURY OR PROTECTED AND/OR SUPPORTED QUARTERLY
6. PIPING SHALL BE THOROUGHLY CLEANED AND BLOWN BEFORE FUNCTIONS TESTING
7. POT & SANITARY PRESS/SET ARE FITTED WITH SAFETY SWITCH, PRESS/GAUGE AND FITTINGS
8. THE POTABLE WTR. TK. SHALL BE COATED W/ONE COAT OF ZINC DUST & FLUSHED PRIOR TO FAUCET
9. FLOW CONTROL VALVES FOR LAUNDRY TUB, GALLEY SINKS, WASH BASINS TO BE INSTALLED DIRECTLY ON TO FAUCET
10. FLOW CONTROL VALVES FOR LAV TO BE INSTALLED ON HOT & COLD LINES
11. WATER HTRS A & B ARE FOR DK. SERVICE BOXES, WASH BASIN IN ENGRM, LAUNDRY TUB, WASHING MACHINE, GALLEY SINK, DISH WASHER & TO LABS.
12. WATER HTRS C & D ARE FOR LAV & SHWRS ON FCSLE DK. AS ALL COMPONENTS OF THE POT WATER SYS. RUNNING IN THE TUNNEL SHALL BE HIGH ENOUGH TO PREVENT ANY WATER FROM FREEZING IN THE TUNNEL THAT MIGHT ACCUMULATE
13. ALL PIPING IN QUARTERS, MESS AND GALLEY PUBLIC SPACES AND NAVIGATING SPACES SHALL BE CONCEALED.
14. ALL VALVES AND VALVES SHALL BE MARKED SHOWING ITS SERVICE AND PARTICULAR LIQUID.
15. ALL PIPING SHALL BE COLOR CODED IN ACCORDANCE WITH MIL-STD-101 AND SHALL INDICATE DIRECTION OF FLOW.
16. SANITARY SYSTEM USE GALV. STL. PIPE ASTM A53 GR B W/ MIL GALV. FITTINGS ASTM A-47.
17. ALL PIPES SUBJECT TO MECHANICAL INJURY OR PROTECTED AND/OR SUPPORTED QUARTERLY
18. PIPING SHALL BE THOROUGHLY CLEANED AND BLOWN BEFORE FUNCTIONS TESTING
19. POT & SANITARY PRESS/SET ARE FITTED WITH SAFETY SWITCH, PRESS/GAUGE AND FITTINGS
20. THE POTABLE WTR. TK. SHALL BE COATED W/ONE COAT OF ZINC DUST & FLUSHED PRIOR TO FAUCET
21. FLOW CONTROL VALVES FOR LAUNDRY TUB, GALLEY SINKS, WASH BASIN IN ENGRM, LAUNDRY TUB, WASHING MACHINE, GALLEY SINK, DISH WASHER & TO LABS.
22. WATER HTRS A & B ARE FOR DK. SERVICE BOXES, WASH BASIN IN ENGRM, LAUNDRY TUB, WASHING MACHINE, GALLEY SINK, DISH WASHER & TO LABS.
23. WATER HTRS C & D ARE FOR LAV & SHWRS ON FCSLE DK. AS ALL COMPONENTS OF THE POT WATER SYS. RUNNING IN THE TUNNEL SHALL BE HIGH ENOUGH TO PREVENT ANY WATER FROM FREEZING IN THE TUNNEL THAT MIGHT ACCUMULATE
LIST OF EQUIPMENT
B/M CONTID
PARTIAL PLAN STBD TUNNEL
PIPING PLAN BELOW MN. DK.
PIPING PLAN
DETAIL "A" POTABLE WATER TANK SUCT
DETAIL "B" TYP. WT. BHD. OR DECK PENETRATION FOR POTABLE WATER SYSTEM ONLY
DETAIL "B" TYP. WT. BHD. PENETR.
DETAIL "B" TYP. DECK PENETR.
TYP. DISCH. ON HOT WTR. HTR.
DETAIL "A-B" DOUBLE LAVATORY COLD WTR. PIPING
DETAIL "A-B" DOUBLE LAVATORY HOT WTR. PIPING
PIPING PLAN
PIPING PLAN
PIPING PLAN